



**TOWN OF WESTWOOD
COMMONWEALTH OF MASSACHUSETTS**

INVITATION FOR BIDS

Structural Column Repair Project

Bid # REC-20-B-001

Addendum 01

July 30, 2019

I. GENERAL INFORMATION FOR ADDENDUM 01

Addendum 01 extends the response due date to **Thursday, August 1, 2019 at 3:00pm.**

Addendum 01 answers the following questions:

Q1 Can you provide the names of firms that attended the site visit?

A1 The firms that attended the site visit are Elizabeth Contracting and Vellucci Welding.

Q2 What outlets are available to contractors for this work?

A2 120V/15A duplex outlets are available to the contractor.

Q3 What is the requirement for the new baseplate?

A3 The existing baseplate is scheduled as 1" thick. The bidding contractor shall carry this thickness. The awarded contractor shall verify in field (V.I.F), confirm thickness with structural and provide to match existing.

Q4 What are the alternative methods of shoring?

A4 The bidding contractor shall bid based on work shown on the construction documents. The awarded contractor may submit alternates to shoring for the engineer's review during the construction phase.

Q5 What is the existing/new column thickness?

A5 The existing column is scheduled as 3/16" thick. The bidding contractor shall carry this thickness. The awarded contractor shall verify in field (V.I.F), confirm thickness with structural and provide to match existing.

Q6 What are regular work hours?

A6 Work hours shall be coordinated with the owner. 6am to 8pm weekdays are the current available hours.

Q7 Can this repair be made without removing and replacing the entire column?

A7 The specification does not state the method of repair but rather the required outcome.



**TOWN OF WESTWOOD
COMMONWEALTH OF MASSACHUSETTS**

II. ADDENDUM 01 RECEIPT ACKNOWLEDGEMENT FORM

BIDDERS **MUST** ACKNOWLEDGE RECEIPT OF ADDENDUM WITH THE BID SUBMITTAL.

Signature _____

Name _____

(Please Print)

Title _____

Company _____

Date _____