



**TOWN OF WESTWOOD
COMMONWEALTH OF MASSACHUSETTS**

INVITATION FOR BIDS

High Street Bonded Wearing Course Project – 2020

Bid # DPW-21-B-010

Addendum 03

August 19, 2020

I. GENERAL INFORMATION

Addendum 03 answers a question.

Q4 With regards to the pavement thickness of the bonded wearing course, what is the thickness of application?

A4 The finished surface treatment shall have a thickness of 5/8 inch to 3/4 inch.

II. ADDENDUM 03 RECEIPT ACKNOWLEDGEMENT FORM

BIDDERS MUST ACKNOWLEDGE RECEIPT OF ADDENDUM WITH THE BID SUBMITTAL.

Signature _____

Name _____

(Please Print)

Title _____

Company _____

Date _____

End of Addendum No. 3